



### CERTIFICATE OF INSPECTING AUTHORITY

Doc. No. M63002/18/MN/mn

I, Matteo Nicoletti being a Surveyor of **Bureau Veritas**, an Inspecting Authority named in the Fourth Schedule to the Factories and Machinery (Steam Boiler and Unfired Pressure Vessel), Regulations, 1970, Malaysia, hereby certify that **(ITEM DESCRIPTION: Steam Boiler / Unfired Pressure Vessel)** Serial No(s). 174450/1 and 174450/2 was/were constructed by Messrs **SAIP S.r.l.** for in accordance with their drawing number APTS.1.3.17.X6.F.B2.40F3.IAX6D2R1

It was surveyed during construction by me and the scantlings are in accordance with ASME VIII Div.1 (being a code name in the Second / Third Schedule to the aforementioned Regulations) for a design pressure of 517,7 pounds per square inch. The workmanship is good.

On completion the **Unfired Pressure Vessel** was/were tested hydrostatically to 827,2 pounds per square inch for a period of 30 minutes in my presence on February 13, 2018.

It Showed no signs of weakness and was found tight and sound in every respect at that pressure. It was stamped by me as follows:



Dated this 13th day of February 2018

(Signed) .....  
Surveyor to Bureau Veritas.



(Signed) .....  
Chief Engineer to Bureau Veritas .